

ECUA RFP NO. 2018-12

Annual Water Well Maintenance and Repair

(October 12, 2018)

ADDENDUM NO. 2

This addendum forms a part of the Bid Documents and clarifies the original Bid Document, dated September 13, 2018, as noted below. This addendum consists of clarifications requested and questions received to date. This addendum consists of two pages and an attachment.

Question Received: Task 5 Item 2: Replace – discharge column

We respectfully request this item be listed as a dated quote, good for one week, as current market prices for carbon steel have fluctuated so much in the past year. **Or will be acceptable to list this as an exception?**

Response: The specification stands as provided. You may list this as an exception.

Clarification Requested: Task 7 Pump Test –

Please clarify if the complete run time is 5 hours total or 3 hours at the specified data points.

Response: Please refer to page 4 of the amended specifications: “The contractor shall submit a plan to ECUA for approval that will allow for 3 points to be established to define the pump curve. In general, it will follow the following criteria: Test pump the well for a period of 3 hours total.”

Correction Requested: Task 8 Disinfection –

AWWA C652 is listed as the standard for Disinfection of Water Storage Facilities

We respectfully request this to be amended to reflect the AWWA C654 standard for Disinfection of Wells.

Response: The AWWA standard is amended as requested to AWWA C654.

Clarification Requested: We would also like to request clarification if ECUA will be responsible for pulling the Bac-T samples.

Response: ECUA will pull Bac-T samples for testing and perform the test. The contractor shall be responsible for the preparation of the sample tap and flushing as required.

Question Received: Is a bid bond required?

Response: No bid bond is required.

Note: The word discharge has been added to the proposal page as applicable. Please see attached amended proposal page.

******* The bid opening has been postponed until 2:00 p.m. local time October 23, 2018, at which time bids submitted will be publicly opened and read. Bids received after 2:00 p.m., local time, October 23, 2018, will be returned unopened. *******

-END OF ADDENDUM NO. 2-