

EMERALD COAST UTILITIES AUTHORITY

RFB NUMBER: 2014 04
TRANSMISSION MAIN INTERRUPTION PLAN COMPONENTS
ADDENDUM NUMBER 3

July 9, 2014

Prospective Bidders:

The previously issued "Request For Bids" (RFB) package has been revised. All prospective bidders must be familiar with the three addendums, original bid package, and modified pages (previously provided) - to make themselves fully aware of the entire requirements under this RFB. Additional questions received at the end inquiry date are addressed below.

1. The part about the long sleeve is kind of confusing because a C153 and a C110 long sleeve are the same length? Still have to be C110? Which AWWA standard for sleeves needs to be met - AWWA C110 or AWWA C153?

From review of AWWA standards, it appears the only differences are the thicknesses and the weights. Therefore, potential suppliers should base their bids on meeting requirements of C110 – for solid sleeves, as previously indicated per addendum.

2. Please clarify bonding requirements for this RFB.

Upon further review and consideration, a bid bond will not be required as originally specified.

For clarification purposes, during the bid opening only the subtotals and totals will be read. Unit pricing will not be read during the bid opening. Unit pricing information will be available after a recommendation to the ECUA Board is made.

If you have any questions, please call my office at 850-969-6531, or email me at amy.williamson@ecua.fl.gov.

Regards,

Amy Williamson, CPPB, FCCM
Senior Purchasing Agent