

EMERALD COAST UTILITIES AUTHORITY
BID CC2015 04

Odor Control Piping

December 4, 2014

ADDENDUM NUMBER 2

Prospective Bidders:

This addendum is issued to answer the following question that was received regarding the specifications in the bid package:

1. Re DWG M-2, Plan A and Section 1...If we are to also provide the drop pipes and diffuser headers with connections for the owner supplied diffusers, we need to be provided a detail on how to fabricate the header, main and branch sizes and connection orientations...we do not design these things. We also need to know what type of expansion coupling is required for the 8 Air line.

Response: We have generated a sketch of the diffuser section that clarifies the orientation and sizes of the pipes and connections that are already called out on drawing M-2. The PermaCap Diffuser product data sheet is also attached for reference. The previous four fabricators did not require this detail and did not feel like they were designing anything. We also typically do not provide isometrics to fabricators.

As far as the expansion joint, that is not in their scope. It is by others. Their work scope starts after the expansion joint and ends at the diffusers.

If you have any other questions, please email me at amy.williamson@ecua.fl.gov.

Regards,

Amy Williamson, CPPB, FCCM
Senior Purchasing Agent