

EMERALD COAST UTILITIES AUTHORITY
BID CC2015 05
CWRF Administration Building and Roof Restoration
December 18, 2014

ADDENDUM NUMBER 2

Prospective Bidders:

This addendum is issued to provide clarification of acceptable roofing product.

A request for substitution from a manufacturer of PVC single ply roofing was received.

Response: The request is denied. Specification requirement for single ply roofing is as repair material only and is specified for PVC roofing manufactured by Johns Manville. The further requirement is to perform all work in order to maintain the twenty (20) year manufacturer warranty from Johns Manville currently in effect.

The only way for a company providing a substitution to provide the remainder of the twenty (20) year warranty would be to provide their material and replace the entire roof areas requiring work. This is obviously not a competitive action.

If you have any questions, please call my office at 850-969-6531, or email me at amy.williamson@ecua.fl.gov.

Regards,

Amy Williamson, CPPB, FCCM
Senior Purchasing Agent