

ECUA BID NO. 2017-05
ANNUAL CONTRACT FOR WEEKLY/MONTHLY RENTAL
OF DIESEL BY-PASS PUMPS AND STORAGE TANKS

November 21, 2016

ADDENDUM NO. 2

This addendum forms a part of the Bid Documents and clarifies the original Bid Description, dated November 3, 2016, as noted below. This addendum consists of One (1) page.

Question Received: “What is the Force Main pressure on Lift station #4 at 9th Ave?”

Response: The force main pressure at Station 4 is 64 PSI or 150 TDH.

-END OF ADDENDUM NO. 2-