

EMERALD COAST UTILITIES AUTHORITY  
RFP NUMBER: 2012 10  
ANNUAL MAINTENANCE OF CATHODIC PROTECTION SYSTEMS  
FOR STEEL WATER STORAGE TANKS FOR ECUA  
June 14, 2012

ADDENDUM NUMBER 1

Prospective Bidders:

This addendum is to notify you of the following information to the above referenced bid number. The following questions were received and the corresponding answers provided:

- **Disposal of water in tank prior to commencing work:** This states that the water will be removed from the tank prior to commencing work. In order to properly test the cathodic protection system water must be in the tank.
  - Thus cathodic protection testing would be done prior to draining the tank and cleaning?
  - Would the tank be drained, cleaned refilled and then the cathodic protection system test be done?

**ANSWER: The testing will be done prior to the tank being emptied.**

- **The proposal states that the contractor must be licensed in the state of Florida.**  
Is this a state business license or a contractor's license? Forms ask for State Corporation information in Florida, is it OK to be incorporated in another adjacent state like Georgia?

**ANSWER: The corporation must have a Florida business license but may be incorporated in a different state.**

- **Are the cathodic protection systems suspended from the roof or are they submerged floating type systems?**

**ANSWER: The existing system is floor mounted.**

If you have any questions, please call my office at 850-969-6531, or email me at amy.williamson@ecua.fl.gov.

Regards,

Amy Williamson, CPPB, FCCM  
Senior Purchasing Agent