

EMERALD COAST UTILITIES AUTHORITY
RFP NUMBER: 2012 10
ANNUAL MAINTENANCE OF CATHODIC PROTECTION SYSTEMS
FOR STEEL WATER STORAGE TANKS FOR ECUA
June 19, 2012

ADDENDUM NUMBER 2

Prospective Bidders:

This addendum is to notify you of the following information to the above referenced bid number. Addendum Number 1 is modified as follows: The following questions were received and the corresponding answers provided:

- Are the cathodic protection systems suspended from the roof or are they submerged floating type systems?

ANSWER: The existing system is roof mounted.

Tank in service: The tank shall remain in service during the annual maintenance. Anodes shall be accessed through the hand holes in the roof. The anodes shall be removed for observation and shall be reinstalled through the hand holes. Any items to come in contact with the anodes shall be disinfected prior to use.

If you have any questions, please call my office at 850-969-6531, or email me at amy.williamson@ecua.fl.gov.

Regards,

Amy Williamson, CPPB, FCCM
Senior Purchasing Agent