

Section 570

Gravity Sewer Collection Systems

PART 1: General

1.1 *General Description of Work* –

- 1.1.1 *Minimum Requirements and Deviations* – The following minimum requirements are considered acceptable to the ECUA in the design of collection systems for wastewater from domestic and commercial customers. Deviations from these standards may be allowed by ECUA only upon a finding by the ECUA that, in accordance with sound engineering standards, the granting of the deviation will not cause or exacerbate operational or maintenance difficulties. No deviation will be allowed unless it is approved in writing by ECUA and is clearly noted on the approved construction plans.
- 1.1.2 *Expansion* – All expansion shall conform to the "Master Plan for Wastewater" as maintained and amended by the ECUA.
- 1.1.3 *Differences with State/Federal Requirements* – When these standards differ from state and/or federal requirements, the more stringent requirement shall apply.
- 1.1.4 *Applicable Appurtenances* – The collection system for wastewater includes the gravity mains, manholes, customer service pipes, lift stations, force mains, and other appurtenances. The system should be designed to provide for the collection of wastewater from the customer and its safe and economical transport to ECUA's Wastewater Reclamation Facilities.

PART 2: Standards

- 2.1 *U.S. Environmental Protection Agency and U.S. Public Health Service* – The governing standards of these agencies will be followed when applicable.
- 2.2 *State of Florida Department of Environmental Protection* – The wastewater collection system shall conform to the applicable State of Florida Department of Environmental Protection (FDEP) laws, policies, standards, rules, and regulations for public wastewater collection systems.
- 2.3 *Plumbing Codes* – The provisions of the Plumbing Code of the City of Pensacola or Escambia County as it pertains to sanitary wastewater collection, service line locations and materials, and onsite plumbing, except as provided for elsewhere in these criteria, shall apply. It is the intent of this standard that the applicable Plumbing Code(s) apply to sewer collection infrastructure constructed beyond the public right-of-way or public utility easements, which does not meet the definition of a "collection system" as defined by the FDEP.
- 2.4 *Recommended Standards for Wastewater Facilities* – Policies for the Design, Review, and Approval of Plans and Specifications for Wastewater Collection and Treatment Facilities; Great Lakes—Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers; 2004 Edition.

- 2.5 *Emerald Coast Utilities Authority* – All wastewater collection systems that are connected to, or to become a part of the ECUA system shall be designed and constructed in accordance with these standards. Materials, installation of materials, and construction methods and procedures shall be in accordance with the current ECUA material and installation specifications. Refer to the Technical Specifications of the ECUA Engineering Manual. All discharges into the ECUA sewer system shall meet the requirements of the ECUA Code.

PART 3: Design Standards For Gravity Sewer Collection Systems

- 3.1 *Flow Requirements* – In sizing the collection system gravity mains, the required design flow shall be the sum of the required sanitary flow as contained below, plus an allowance for infiltration and inflow.
- 3.1.1 *Required Sanitary Flow (Residential)* – Required average daily flow for sanitary use in residential areas shall be based on 300 gallons per day per unit or as approved by the ECUA.
- 3.1.2 *Required Sanitary Flow (Nonresidential)* – The required flow for commercial, industrial, or other nonresidential areas shall be as determined by the Engineer and approved by the ECUA for each specific instance. Refer to State of Florida Department of Health Chapter 64E-6 Florida Administrative Code Table 1.
- 3.1.3 *Required Allowance for Inflow and Infiltration* – The maximum required allowance for infiltration and inflow for developed areas shall be in accordance with the following table: (Based on 25 gpd/inch dia./mile for new construction)

Inflow and Infiltration Allowance	
Pipe Diameter (inches)	Max. Allowance I & I Flow (GPD/1000 ft.)
8	38
10	47
12	57
24	114
30	142
36	170

- 3.1.4 *Peak Flow* – Peak factors shall be applied to the calculated flow in accordance with Figure. 1, "Ratio of Peak Hourly Flow to Design Average Flow" as taken from the Recommended Standards for Wastewater Facilities, Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, most recent edition.
- 3.2 *Future Interconnections* – Provisions for future connecting mains shall be made by providing appropriate easements and/or extending construction of all wastewater mains to the exterior boundaries of the subdivision or development wherever future connections to adjacent subdivisions or lots are anticipated.
- 3.3 *Gravity Collection Mains* – Gravity mains shall be of sufficient size to carry the required flow at velocities as herein provided. Mains shall be located to provide service to each lot within a development as herein provided. All mains shall be installed only in public rights-of-way or utility

easements, in favor of the ECUA for the use and benefit of the ECUA. All main locations and sizes shall be in accordance with the ECUA's current "Master Plan for Wastewater" and the ECUA-approved development plan and utility layout.

- 3.3.1 *Minimum and Standard Main Size* – Minimum gravity main diameter shall be 8 inches in all areas. Standard sizes of gravity mains used shall have nominal diameters of 8, 10, 12, 15, 18, 24, 30, and 36 inches.
- 3.3.2 *Minimum Allowable Slope* – Slopes shall be designed with a hydraulic gradient sufficient to prevent deposition of solids, by developing a minimum velocity of 2.0 feet per second as computed using Manning's formula and a "n" value of not less than .013 while flowing full. The following table establishes the minimum allowable slopes for various size pipe.

Minimum Allowable Slope for Sewer Mains	
Pipe Size (inches)	Minimum Slope (%)
8	0.4
10	0.28
12	0.22
15	0.15
18	0.12
24	0.08
30	0.06
36	0.05

Under special conditions, if full and justifiable reasons are given, slopes slightly less than those required for the 2 feet per second velocity when flowing full may be permitted. Such decreased slopes will only be considered where the depth of flow will be 0.3 of the diameter or greater for design average flow. Whenever such decreased slopes are selected the Engineer must furnish with his report his computations of the depths of flow in such pipes at minimum, average and peak rates of flow. It is recognized that such flatter grades may cause additional sewer maintenance expense and odor nuisance. The selection of the size of pipe shall be determined on the basis of the most desirable flow characteristics obtainable. The Owner of any privately maintained sewer system will give written assurance to the appropriate reviewing agency that any additional sewer maintenance required by reduced slopes will be provided.

- 3.3.2.1 In the case of sewers where the slope and volume are such that velocities will exceed 10 feet per second at average flow, special provision shall be made to protect against erosion. This protection may be secured utilizing C900 PVC, ductile iron, steel pipe or equivalent, when approved in writing by the ECUA.
- 3.3.2.2 Where velocities greater than 15 feet per second are anticipated, special provision shall be made to protect against displacement by erosion and shock.
- 3.3.2.3 Sewers on 20 percent slopes or greater shall be anchored securely with concrete anchors or equal, spaced as follows:
 - 3.3.2.3.1 Not over 36 feet center to center on grades 20 percent and up to 35 percent,
 - 3.3.2.3.2 Not over 24 feet center to center on grades 35 percent and up to 50 percent; and

- 3.3.2.3.3 Not over 16 feet center to center on grades 50 percent and over.
- 3.3.2.4 Full advantage of suitable topography and paralleling of ground slopes shall be made. Minimum slopes should only be used when necessary, particularly with 8-inch pipe. When depth exceeds 10 feet, check pipe class for strength, and/or specify stricter bedding requirements.
- 3.3.2.5 Sewers shall be designed and laid with a uniform slope between manholes.
- 3.3.3 *Pipe Size Between Manholes* – Change in pipe size shall not occur between manholes.
 - 3.3.3.1 *Increasing Size* – When a smaller sewer joins a larger one, the invert of the larger sewer shall be lowered sufficiently to maintain the same hydraulic gradient. The crowns of pipes shall be at the same elevation within the manhole.
 - 3.3.3.2 *Decreasing Size* – At times, due to increasing sewer slopes, a reduction in the size of the outgoing sewer from a manhole may be justified. Such a reduction shall not be permitted on sewers 24-inch in diameter or under, but may be permitted on sewers larger than 24-inch in diameter. Inverts of the pipes shall be matched in the manhole.
- 3.3.4 *Crossing Other Utilities* – When crossing other utilities, vertical separation shall be shown.
- 3.3.5 *Change in Horizontal Alignment* – There shall be a drop of 0.1 foot across each manhole.
- 3.3.6 *Crossing Existing Roads* – When crossing under existing paved streets or roads, it must be determined if open cut will be permitted. If jack and boring will be required complete details must be shown. Extra effort should be expended to locate any possible conflict with existing utilities. Allow extra slope through bore and specify minimum and maximum allowable deviations.
- 3.3.7 *Collection System Depth* – The depth of the collection system shall be sufficient to receive flows by gravity from all buildings and lots to be served. The service lines shall be installed in accordance with plumbing code(s) specifications and slopes. A 30-inch minimum cover shall be required. Less cover may be considered with special provisions for protection of the pipe.
- 3.3.8 *Privately Maintained Stations* – Connections of individual properties and buildings to the ECUA wastewater collection system shall be accomplished by gravity flow to the maximum extent practicable. When no reasonable alternative exists, privately maintained lift stations may be employed, with ECUA consent, for connection to the collection system. All such systems necessary for connection to the ECUA collection system shall be privately maintained.
- 3.3.9 *Alignment* –
 - 3.3.9.1 Sewers shall be laid with straight alignment between manholes.
 - 3.3.9.2 Horizontal separation from other utilities shall be maintained.
 - 3.3.9.3 Sewers 48-inch and larger may be laid on a curve. Refer to pipe manufacturer for allowable curvature.

- 3.3.9.4 Changes in horizontal alignment of greater than 90° are to be avoided.
- 3.3.10 *Pipe Material* – PVC pipe SDR26 shall be utilized for gravity lines. C900 PVC or DI pipe may be substituted where extra strength or joint integrity is required.
- 3.3.10.1 Pipe material will not be changed between manholes (except where additional structural protection is required).
- 3.3.10.2 Where ductile-iron pipe is to be installed, external pipe corrosion protection will be specified if soil resistivity is less than 1,000 ohms per square centimeter per centimeter. (Polyethylene sleeves or an anticorrosion embedment as directed by the ECUA.) Internal pipe corrosion protection shall be provided by proven Hydrogen Sulfide and abrasion resistant coatings. Fused Epoxy coating is recommended, others shall be approved by ECUA Engineering Department.
- 3.3.11 *Cover* –
- 3.3.11.1 A minimum cover of 30 inches must be provided where conditions permit.
- 3.3.11.2 At road crossings, a minimum separation distance of 24 inches shall be maintained from the bottom of the roadway base to the top of the pipe or the top of the casing when provided.
- 3.3.11.3 At buried stream crossings, a minimum cover of 36 inches is required.
- 3.3.12 *Crossings* –
- 3.3.12.1 Major road crossings shall be encased per Section 2310-“Jack and Bore” of Standard Specifications or made using ductile iron pipe. Additional requirements of the regulatory agency responsible for the road shall be met.
- 3.3.12.2 Buried stream crossing shall be encased in steel casing or made with ductile iron pipe. This protection shall extend 10 feet beyond the bank and the pipe or casing shall be anchored to prevent shifting.
- 3.3.12.3 Aerial stream crossing shall be encased in steel casing or made with ductile iron pipe. This protection shall extend until 30 inches of cover is provided.
- 3.3.12.4 When crossing under pipes, conduits or other structures greater than 24 inches in diameter, and a 6-inch separation distance cannot be maintained, the pipe shall be encased in steel casing or made with ductile iron pipe for a minimum of 10 feet distance on either side of the crossed pipe.
- 3.3.13 *Manholes* – Manholes shall be installed at the end of each sewer line, at all junctions, at all changes in grade, size, or alignment; with the following added considerations:
- 3.3.13.1 Maximum spacing shall be 400 feet up to and including 36-inch pipe, controlled by available ECUA cleaning equipment. Spacing for pipes larger than 36-inch may be increased up to, but not to exceed 500 feet, controlled by cleaning requirement.
- 3.3.13.2 Lampholes shall not be used on any gravity sewer line. Manholes shall be provided at the end of every sewer line.

- 3.3.13.3 Manholes located in the roadway shall be placed in the center of the roadway or travel lane if possible to avoid wheel traffic.
- 3.3.13.4 A drop manhole shall be provided when a sewer invert enters a manhole at an elevation of 2 feet or more above the manhole invert. Where the difference in elevation is less than 2 feet, the invert shall be formed to a half-round concrete channel of equivalent diameter of the outlet pipe to prevent solids deposition. Drop manholes shall use an outside drop connection, except inside drops may be approved for building services and laterals. Inside drops shall be securely fastened to the interior wall of the manhole with stainless steel clamps or pipe hangers. Inside drops shall be extended to the invert of the manhole on a 45-degree bend installed to direct flow correctly. The drop shall be installed so it does not block manhole access or inhibit maintenance. See ECUA Detail D-13, "Drop Manhole Connections."
- 3.3.13.5 The inside diameter of manholes shall be a minimum of 48 inches up to and including 24-inch pipe. For pipe larger than 24 inches, the inside diameter of the manhole shall be increased so as to provide at least a 12-inch shelf on each side of the pipe.
- 3.3.13.6 Manholes shall be precast reinforced concrete unless special conditions would dictate a cast in place or other type.
- 3.3.13.7 The manhole flow channel shall ensure a smooth flow line from all incoming lines to the outgoing. All channels must provide a smooth transition to the outgoing line with the maximum possible radius on all curves. Precast manhole channels or inverts may be approved, but only if they meet the above requirements. Channels shall have the equivalent diameter of the manhole effluent pipe.
- 3.3.13.8 Ventilated manholes may be required by the ECUA Engineering Department as conditions dictate. Ventilation methods shall be approved by the ECUA Engineering Department in writing before installed.

3.4 *Wastewater Services* –

- 3.4.1 *Service Laterals* – Service laterals shall be provided to all lots within a subdivision in accordance with the ECUA regulations. All residential service laterals shall be located in the center of the property line nearest to the collection system. Customer service connections to industrial or commercial lots may be omitted provided approval of the ECUA is obtained prior to approval of plans and specifications.
- 3.4.2 *Flow Measurement* – The ECUA may require flow measuring devices where flows in excess of 50,000 gpd can be expected. This includes apartment complexes, trailer parks, shopping centers, etc. The ECUA must approve the method and location of flow measurements. Acceptable methods will include pre-approved open channel flow devices with meter/totalizer, pipe meters and hour meters on private lift stations.
- 3.4.3 *Cleanouts* – A two-way cleanout shall be installed at the property line or otherwise approved by the ECUA Engineering Department.