



NOTE:

1. SEE SECTION 2570 FOR COMPLETE SPECIFICATIONS
2. VACUUM TEST TO BE COMPLETED IN ACCORDANCE WITH ASTM C-1244 AND PERFORMED PRIOR TO BACKFILLING
3. SUPPORTING SOILS UNDER THE BASE OF THE MANHOLE SHALL BE COMPACTED TO AT LEAST 98% OF MAXIMUM DENSITY



PROPOSED

SCALE: N.T.S.
DATE: 12/18/14

STANDARD MANHOLE

DETAIL

D-10