



NOTES:

1. RESIDENTIAL PUMP STATION SHALL BE MAINTAINED BY THE CUSTOMER. IT IS RECOMMENDED THAT ALL PUMP STATIONS SHALL BE A SEMI-POSITIVE DISPLACEMENT TYPE. A CHECK VALVE AND BALL VALVE SHALL BE PROVIDED AT THE PUMP STATION AND MAINTAINED BY THE CUSTOMER.
2. EACH CUSTOMER SHALL HAVE A SEPARATE "LOW PRESSURE RESIDENTIAL SEWER SERVICE" (SEE ABOVE DETAIL). ALL COMPONENTS ON CUSTOMER SIDE OF METER BOX ARE RESPONSIBILITY OF CUSTOMER.
3. IF LONG SERVICE (UNDER ROAD), PROVIDE 2" GREEN PE CASING, MIN. 24" COVER UNDER ROADWAY AND/OR DITCH.

LOW PRESSURE RESIDENTIAL SEWER SERVICE

DETAIL

D-20



SCALE: N.T.S.
DATE: 12/18/14