

EMERALD COAST UTILITIES AUTHORITY
RFP Number 2010-09
STAINLESS STEEL TANKS FOR PCB WWTP
OPENS May 18, 2010

ADDENDUM NO.1
APRIL 19, 2010

Dear Sir:

This addendum is to notify you of the following information to the above referenced bid number. Please add the following to the specifications section. The remaining information is to stay the same.

- All welding to be done by ASME certified welders.**
- All stainless steel surfaces to receive ASTM A-380 mechanical clean process at the factory.**
- Anything less would require a manufacturer to provide a deductive alternate.**

If you have any questions, please call my office at 850-969-3350 extension 2415 or email to Amy Williamson (awilliamson@ecua.org)..

Sincerely,

Amy Williamson
Senior Purchasing Agent